



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE
APPENDIX - 3 (Chapter -III Rule:24)

Certified that **M/S. VIJAYA VIDHYALAYA SENIOR SECONDARY SCHOOL, S.F.No. 414/2B, 415/1C, BYPASS ROAD, ODDERPALAYAM VILLAGE, PALLAPALAYAM TOWN PANCHAYAT, SULUR BLOCK & TALUK, COIMBATORE -641016** has been inspected on **03.03.2025** and the building and premises are found satisfactory on the following aspects.

- The accommodation provided for each of the class rooms is sufficient for the minimum number of students stay.
- Ventilation, lighting that the building is maintained in substantial repair and Sanitary arrangements provided are adequate and satisfactory.
- The latrine arrangements are adequate and satisfactory.
- The supply of drinking water is wholesome and good.
- Premises and surrounding are maintained neat and clean.

THIS CERTIFICATE IS ISSUED SUBJECT TO THE FOLLOWING CONDITIONS:

- On any account the garbage shall not be burnt or kept more than 24 hours in the premises and should be collected and disposed by appointing required sanitary staff.
- Usages of plastics in less than 40 microns thickness is prohibited.
- Fire pre cautionary measures and first aid box should be provided.
- Child Labour should not be engaged on any account.
- Overhead Tank and water sump shall be hermetically sealed and scientifically closed and shall not be breeding sources of mosquitoes.
- Drinking water shall be chlorinated and shall have 0.5ppm of residual chlorine.
- Fly/ Mosquitoes breeding shall not be permitted within the premises.
- COVID-19 - Epidemic Disease Act, 1897 (Central Act 3 of 1897), Tamil Nadu Public Health Act 1939 Section 62 & 76 Regulation and SOP should adhered strictly by the institution.

- Display and exhibition of board: as per rule 3 of the Tamilnadu prohibition and smoking and spitting rules 2003.
 - Every person in charge of public work or use shall display and exhibit a board at a conspicuous place in or outside the place prominently stating the place is as "No smoking and No spitting place" and that "Smoking or spitting here is an offence" which shall be both in Tamil and English and the version in English shall be in the second place below than Tamil.
 - The Tamil version shall be written predominantly in the board by providing more space than English.

This certificate is liable to be cancelled at any time on infringement if any of above said conditions and for improper maintenance of sanitation & Building and, if any, health nuisance is found as defined in Tamil Nadu Public Health Act, 1939.

Certificate is valid for the period of One year from the Date of issue.

Place: SOMANUR
Date : 03.03.2025

Dr. [Signature]
03/03/2025
Block Health Supervisor
Govt. Primary Health Centre,
Somanur, Coimbatore.

L.Dis.No. 01538/A2/2025 Dt.03.03.2025
Counter Signed

[Signature]
13/03/2025
DISTRICT HEALTH OFFICER
COIMBATORE.

[Signature]
11/03/25



ENVIRO FARMERS LABS & TESTING SERVICES (OPC) PRIVATE LIMITED



SERVICES :

- Water and Wastewater Testing
- Environmental Monitoring & Testing
- Testing of Food and Food Products
- Soil, Compost & Solid Waste Testing
- Microbial Testing Services
- All Other Environmental Testing Services

CONTACT US :

Address : No-2/83, Avinashi Main Road,
Chinnampalayam Post, Sulur Taluk,
Coimbatore - 641062, Tamilnadu, India.
Phone : + 91 9042855456 + 91 7530035465
+ 91 9952855456 + 91 7530035470
E-Mail : envirofarmerslabtech@gmail.com
Website : www.eftlcb.com

ACCREDITATIONS :



TEST REPORT FOR WATER ANALYSIS

| Report No | EFLT/TR/WA/2024/0108 | Report Date | 16.05.2024 | | |
|--|--|--|-------------------|---------------|--|
| CUSTOMER DETAILS | | | | | |
| Name & Address of the Customer/Company | | M/s.VIJAYA VIDHYALAYA SCHOOL, A Unit Of Sree Vijayalakshmi Charitable & Educational Trust, 19 G, L & T Bye PASS Road, Ondipudur,Coimbatore - 641016, Tamilnadu, India. | | | |
| DETAILS OF SAMPLE | | | | | |
| Nature of Sample | Water | Sample Quantity | 1 Litre | | |
| Customer Code | Water | Laboratory Code | EFLT/WA/2024/0108 | | |
| Sample Collected On | 13.05.2024 | Sampled By | Customer | | |
| Sample Received On | 13.05.2024 | Analysis Started Date | 13.05.2024 | | |
| Received Condition | Packed in a Sterile Container | Analysis Completed Date | 16.05.2024 | | |
| Sample Description | Colorless, Clear, Transparent Liquid. | | | | |
| TEST REPORT PARTICULARS | | | | | |
| S.no | Parameters | Test Method | Unit | Result | Standard As Per IS 10500:2012 |
| 1 | Color | IS 3025 (Part-04) | Hazen | < 5.0 | 5 Max |
| 2 | Odour | IS 3025 (Part-05) | - | Agreeable | Agreeable |
| 3 | Taste | IS 3025 (Part-08) | - | Agreeable | Agreeable |
| 4 | Turbidity | IS 3025 (Part-04) | NTU | 0.1 | 1.0 |
| 5 | pH @25°C | IS 3025 (Part-11) | - | 7.12 | 6.5-8.5 |
| 6 | Electrical Conductivity @25°C | IS 3025 (Part-14) | µS/cm | 35.0 | - |
| 7 | Total Dissolved Solids @180°C | IS 3025 (Part-16) | mg/L | 20.0 | 500.0 |
| 8 | Total Alkalinity as CaCO ₃ | IS 3025 (Part-23) | mg/L | 5.00 | - |
| 9 | Chloride as Cl ⁻ | IS 3025 (Part-32) | mg/L | 7.00 | 250.0 |
| 10 | Total Hardness as CaCO ₃ | IS 3025 (Part-21) | mg/L | 7.00 | 200.0 |
| 11 | Calcium as Ca | IS 3025 (Part-40) | mg/L | 1.60 | 75.0 |
| 12 | Magnesium as Mg | IS 3025 (Part-46) | mg/L | 0.73 | 30.0 |
| 13 | Total Residual Chlorine as Cl ₂ | IS 3025 (Part-26) | mg/L | BDL[DL-0.1] | 0.2 |
| 14 | Sulphate as SO ₄ | IS 3025 (Part-24) | mg/L | 1.22 | 200.0 |
| 15 | Nitrate as NO ₃ | IS 3025 (Part-34) | mg/L | 0.53 | 45.0 |
| 16 | Total Iron as Fe | IS 3025 (Part-53) | mg/L | 0.037 | 0.3 |
| 17 | Fluoride as F | IS 3025 (Part-60) | mg/L | 0.16 | 1.0 |
| 18 | Arsenic as As | IS 3025 (Part-37) | mg/L | BDL[DL-0.01] | 0.001 |
| 19 | Copper as Cu | IS 3025 (Part-42) | mg/L | BDL[DL-0.01] | 0.01 |
| 20 | Zinc as Zn | IS 3025 (Part-49) | mg/L | 0.67 | 5.0 |
| 21 | Cadmium as Cd | IS 3025 (Part-41) | mg/L | BDL[DL-0.001] | 0.01 |
| 22 | Lead as Pb | IS 3025 (Part-47) | mg/L | BDL[DL-0.01] | 0.01 |
| 23 | Mineral Oil | IS 3025 (Part-39) | mg/L | BDL[DL-0.5] | 0.5 |
| 24 | E Coli | IS: 1622 | CFU/ml | Absent | Shall not be detected in any 100 ml sample |
| 25 | Coliform | IS: 1622 | CFU/ml | Absent | |

Note: BDL-Below Detectable Limit; DL- Detectable Limit

Remarks: The Tested Water is Physically, Chemically Potable and Biologically Not Contaminated.

Hence the above tested sample report meets the requirement of Drinking water quality as per IS: 10500:2012 Based on above Tests.

End of Report



S.P. Mohanraj
Authorized Signatory
S.P. Mohanraj
Technical Manager

Terms & Conditions :

- ❖ The Above Test Results Relate Only to the Samples Submitted for Laboratory Analysis.
- ❖ The Test Report shall not be Reproduced in Full or Part without the Written Consent of EFLT- CBE-62.
- ❖ The Test Items will be Retained for 15 Days from the Date of Issue of Test Reports.